



The 2017 Seattle Wedding Show Fire Marshal Requirements

The following items are required by the Seattle Fire Marshal's Office for booths at trade shows or otherwise used for display within the City of Seattle limits.

FLAME PROOFING

All decorative materials hung in a vertical manor must be meet the NFPA 701 code. Either by being tagged that it meets the code or with a certificate by a third party that it has been treated with a flame proofing treatment.

To facilitate verification that an item described above is flame retardant; the following options may be used:

1. A copy of the Certificate of Flame Resistance for the item may be left in the booth when the vendor does not occupy it. The Certificate of Flame Resistance must indicate the item meets the requirements of either **National Fire Protection Association 701 (NFPA 701) and /or the State of California Fire Marshal** approved standard for flame proofing (Note: **Certificates of Flame Resistance are valid for one (1) year** after which time they must be renewed. Unless the certificate shows expiration date stating otherwise or indicates the treatment cannot be removed when laundered.)
2. A tag or label affixed to the item indicating it meets either the NFPA 701 and/or The State of California Fire Marshal approved standard for flame proofing.
3. Only certificates from a third party certifier or manufacturer of the product(s) are acceptable. Treating the item(s) yourself shall no longer be acceptable.

The use of oilcloth, tarpaper, sisal paper, nylon, Orlon and certain other synthetic materials that cannot be made flame resistant is strictly prohibited.

Items which are not accompanied by a valid Certificate of Flame Resistance shall be removed. If the item(s) is unable to be removed from the show floor prior to the showing opening, the show doors may be held and/or the vendor/exhibitor's booth may be closed!

COMBUSTIBLE STORAGE

Combustible storage –repacking material, etc. is prohibited throughout the public assembly area. This includes areas in and behind individual booth spaces. NOTE: Small amounts of brochures and other literature for distribution may be stored under tables but must be kept 18" away from electrical cords.

No lit candles will be allowed in any booth at any time.

If you need decorative materials or drapes treated please contact:

American Flame Coat 206-789-9404

They can treat and provide certification of your materials

There is a minimum fee, call for pricing.

Or here is a link to their information:

http://weddingshow.com/Updated_Items/vendor_documents/americanflamecoat.pdf

Booth and Displays

1. Do not encroach on aisles that border your booth.
2. Fire Extinguishers, Hose Cabinets, Fire Exits or Fire Alarms cannot be blocked or covered.
3. Storage in your booth is acceptable as follows:
 - a. Boxes, packing materials, waste and debris must be removed prior to the start of the show and kept picked up during the show.
 - b. All areas are inspected periodically.
 - c. Boxed brochures, product and sales material storage may be allowed if kept orderly and not stored behind pipe and drape.
4. There is no smoking in the Exhibition Center.

Extension Cords and Plugs

1. All extension cords must be a minimum of 14 gauge, 3 wires and grounded.
 - a. Use ties or cable clamps when running cord.
 - b. Lightweight extension cords or "zip cords" may not be used.
2. Breaker (Power) strips are approved for additional outlet plugs.
 - a. Cube tabs are not allowed.
 - b. Power strips cannot be "daisy chained"
3. Cords, plugs and strips must have UL labeling.

Tenting, Canopies or Awnings

Tents, Canopies, awnings or coverings over a booth require permission from show management. No booth or its neighboring booths can continuously cover more than 300 square feet. You will also be required to have a fire extinguisher (2A 10BC minimum UL classification) and a smoke detector (at the highest point in the tent) within the booth.

Open Flame

- a. No lit candles are allowed
- b. Sterno cook tops do not require a permit, but a fire extinguisher is required in your booth.

Portable Fire Extinguishers

1. It is highly recommended that you have a fire extinguisher for your exhibit. Depending on your exhibits content, the Fire Marshal may require that you have one.
2. Your fire extinguisher must have a UL rating A 2A 10BC rating.
3. Your extinguisher must be inspected and serviced annually.

Vehicle Displays Requirements

1. Maximum Fuel: $\frac{1}{4}$ of a tank or 5 gallons whichever is less.
2. All gas covers shall be taped or have a locking type gas cap.
3. Battery cables shall be disconnected and taped.
4. Vehicles with no fuel gauge or with a broken fuel gauge shall not be allowed on the event floor, unless a representative of the Fire Marshal's office gives prior approval.

Permits or Questions? Please Call the Fire Marshals' Office at 206-386-1450 or visit

<http://www.cityofseattle.net/fire/fmo/specialevents/sehome.htm>

The Fire Marshal will be at the Convention Center during Show Setup on Thursday and Friday and before show opening on Saturday January 14, 2017. They will be checking to be sure that all exhibitors of the show are in compliance. They will also visit the Show during show hours.